

FORMALDEHYDE ATTESTATION

FORMALDEHYDE ATTESTATION OF PLYWOOD

Okoume, Poplar and Maritime Pine

The THEBAULT GROUP produces Okoumé Plywood Poplar Plywood and Maritime Pine Plywood. The production sites and trademarks are listed in the table below:

1	2	3	4	4
Plywood 100% Okoume	Plywood Okoume faces Poplar cores	Plywood 100% Poplar	Plywood 100% Maritime Pine	Contreplaqués 100% Silver Fir
THEBAULT JEAN - 79460 MAGNÉ			SIB THEBAULT - 79190 SAUZÉ-VAUSSAIS THEBAULT PLY-LAND - 40210 SOLFÉRINO	THEBAULT JEAN - 79460 MAGNÉ SIB THEBAULT - 79190 SAUZÉ-VAUSSAIS THEBAULT PLY-LAND - 40210 SOLFÉRINO
TEBOFLAM TEBOGARANT TEBOMARINE TEBOPAINT TEBOPLY TEBOPRIME TEBOPROFIL TEBOSTILE	TEBOPLY COMBI TEBOTWIN	TEBOPLUS	TEBOBETON TEBOPIN III TEBOPIN CONTREVENTEMENT TEBOPIN ELITE TEBOPIN FLAM TEBOPIN SELECT TEBOPIN STANDARD TEBOPIN STAR TEBOPIN WEATHER SCREEN TEBOROOF WEATHER SCREEN	TEBOFLOOR TEBOPIN CLEAR TEBOPIN EUROANEL TEBOPIN PROFIL TEBOPIN SOLID TEBOWALL TEBOSILVER II/III TEBOSILVER III/III TEBOSILVER FLOOR TEBOSILVER ROOF

The panels listed in the table above are in conformity with the normative requirements of the European Union n°1907/2006 amended by regulation 2023/1364 of 14 July 2023:

Formaldehyd klasse (EN 717-1): E0.5 (≤ 0,062 mg/m³)

► **Formaldehyde classification Okoume plywood (*Aucoumea Klaineana*)**

IAW test report N° 402/19/1150C/2-f-e FCBA dated 7th of October 2019 IAW EN 717-1:

Formaldehyde emission result: not detected < 0.01 mg/m³

► **Formaldehyde classification Poplar plywood (*Populus SPP*)**

IAW test report N° 402/11/1172C FCBA dated 10th of November 2011 IAW EN 717-1:

Formaldehyde emission result = 0,01 mg/m³

► **Formaldehyde classification Maritime Pine plywood (*Pinus Pinaster*)**

IAW test report N° 402/19/1150C/1-f-e FCBA dated 7th of October 2019 IAW EN 717-1:

Formaldehyde emission result = 0,01 mg/m³

IAW test report EUROFINS dated 14/07/2023 IAW EN 16516:

Formaldehyde emission result ≤ 0,015mg/m³

► **Formaldehyde classification Silver Fir (*Abies Alba*)**

IAW test report EUROFINS dated 21/06/2023 IAW EN 717-1:

Formaldehyde emission result ≤ 0,0026 mg/m

IAW test report EUROFINS dated 21/06/2023 IAW EN 16516:

Formaldehyde emission result ≤ 0,0064 mg/m³

Antoine THEBAULT
Président




www.groupe-thebault.com

Groupe THEBAULT - 47, rue des Fontenelles - 79 460 MAGNE - France
Tél : +33 (0)5 49 35 70 20 - info@groupe-thebault.com